

ATS

操作手冊 **WS1-TC**軟水/砂濾/
活性炭/除鐵機/錳砂過濾

系統設定 1

設定砂濾\軟化參數設定分鐘




同時按下3秒



再同時按3秒進入系統



軟化設定P2



設定補水分鐘

動作	All Times in Minutes				
	1 st 逆洗	C2 吸鹽慢洗	2 nd 逆洗	C4 正洗	C5 補水
P0	3	50	3	3	1-99
P1	8	50	8	4	1-99
P2	8	70	10	6	1-99
P3	12	70	12	8	1-99
P4	10	50	Skipped	8	1-99
P5	4	50	Skipped	4	1-99
P6	12	6	Skipped	12	1-99
P7	6	Skipped	Skipped	4	Skipped
P8	10	Skipped	Skipped	6	Skipped
P9	14	Skipped	Skipped	8	Skipped

砂濾設定

設定99天設定 系統設定2

Regen Min. Fill Regen Hour **99** Time - Hour PM Days To Regen



設7或99天再生壹次
請設定99

Regen Min. Fill Regen Hour **60** Time - Hour PM Days To Regen



設頻率50HZ或60HZ
請設定當地60HZ頻率

Regen Min. Fill Regen Hour **dP** Time - Hour PM Days To Regen




設定訊號五分鐘啟動

Regen Min. Fill Regen Hour **dP** Time - Hour PM Days To Regen



五分鐘啟動延時再生
請設定這膜式



Regen Min. Fill Regen Hour **2** Time - Hour PM Days To Regen



設定再生時間
請設定2點

Regen Min. Fill Regen Hour **4** Time - Hour PM Days To Regen



設定幾天再生一次
請設定2點

設定星期再生 設定開始3~1

同時按下3秒



再生時間(am2:00)



設定今天日期(星期一)




星期日未設定再生



Display	Day of Week
d1	Sunday 日
d2	Monday 一
d3	Tuesday 二
d4	Wednesday 三
d5	Thursday 四
d6	Friday 五
d7	Saturday 六

設定開始3~2

設定星期一未設定再生



再生



設定星期二再生



設定星期三未設定再生





設定星期四未設定再生

設定開始3~3

再生



設定星期五再生

設定星期六未設定再生





Exit

時間及手動再生設定



1. 按住一下閃爍後設定現在時間,再按一不閃爍設定完成

2. 按上下改變顯示




手動再生~兩鍵同時按下3秒,手動再生啟動


設定再生\動作時間\錯誤訊息顯示

Set clock:

再生動作顯示




Displays current regeneration cycle



顯示 表示下午pm


錯誤訊息



If “E1,” E2” or E3 appears on the display contact the OEM for help. This indicates that the valve did not function properly.

如顯示E1~E2~E3表示失去功能請洽OEM

A訊號再生接點\接點介紹



C馬達接點

C電源接點

NOTE: A regeneration will be initiated or scheduled after the control has received a signal for five minutes.

A. Differential pressure switch connection

B. Motor wire connection

C. Transformer wire connection